

NOTICE OF SPECIFIED PENALTY

Date of Issue: March 2, 2017		Payment Due Date: April 3, 2017	
MSA File Number	2017-021	Specified Penalty Amount	\$1,500
Registered Entity Name	Genalta III GP Ltd.		
Asset ID (if applicable)	WCD1	Self-Report	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
ISO Rule	203.4	Date of Contravention	October 9, 2016
Date of Referral/Self Report	January 23, 2017	This is the first contravention by this asset for this rule within a rolling 12 month period.	

EVENT DETAILS

On October 9, 2016, from approximately 00:22 to 05:52, the WCD1 generating asset was dispatched at 15 MW of energy however, WCD1 generated below its allowable dispatch variance (ADV) during this interval. ISO rule section 203.4 states that a pool participant must not, during generating asset steady state, vary the average MW it delivers from a generating source asset in any 10 minute clock period from the dispatch MW by more than the allowable dispatch variance.

FINDINGS

Based upon the information obtained by the MSA, the MSA is satisfied that the event was a contravention of ISO Rule 203.4.

MATERIAL FACTS

The material facts relied upon by the MSA include the following:

1. AESO generation and dispatch data for WCD1 for October 9, 2016.
2. AESO information request issued to Genalta III GP Ltd. dated January 6, 2017.
3. Genalta III GP Ltd.'s response to the AESO information request dated January 18, 2017.
4. Referral from the AESO to the MSA dated January 23, 2017.

DELIVERY OF PAYMENT

Payment by cheque or certified funds is to be made out to the "General Revenue Fund c/o Minister of Finance", and delivered to the Alberta Utilities Commission (AUC) at: 4th Floor, 425 - 1st Street S.W., Calgary, Alberta, T2P 3L8. Questions in respect of delivery of payment should be addressed to the Director of Finance, AUC. The payment should reference this notice and related MSA File #. Delivery of payment should also be confirmed by email to compliance@albertamsa.ca, with copy to the following AUC personnel: Sabi Ghavami (Director, Finance) sabi.ghavami@auc.ab.ca, and Greg Andrews (Investigator) greg.andrews@auc.ab.ca.

NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the Alberta Utilities Commission Act to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened a reliability standard. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC. In accordance with s. 5(1) of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at compliance@albertamsa.ca.

SIGNATURE

Signature	"Original Signed"	Signature Date	March 2, 2017
Name	Doug Doll	Title	Director, Compliance and Corporate Services